



Proprietary and
Confidential

The information contained in this drawing is the sole property of
Spoerr Precast Structures LLC.
Any reproduction in part or as
whole without the written
permission of
Spoerr Precast Structures LLC.
is prohibited.

Spoerr Precast Structures LLC.

2020 Caldwell St
Sandusky, OH 44870
419-625-9132

Concrete 5000 PSI @ 28 Days
Max cover on top of tank 48"

Minimum Cover 6"
Inlet boots for 4" pipe
Outlet Boots for 2" Pipe
Boots: Meet ASTM C923
Sealant: Meets ASTM C990
208 Gallon/inch

1000 Gallon Pump Tank

Excavation 6' x 9'

02/26/26
