



Proprietary and Confidential

The information contained in this drawing is the sole property of

Spoerr Precast Structures LLC.

Any reproduction in part or as whole without the written permission of

Spoerr Precast Structures LLC. is prohibited.

# Spoerr Precast Structures LLC.

2020 Caldwell St

Sandusky, OH 44870

419-625-9132

Concrete 5000 PSI @ 28 Days  
Max cover on top of tank 48"

Minimum Cover 5'

Inlet boots for 4' pipe

Outlet Boot for 2' Pipe

Boots meet ASTM C923

Sealant: Meets ASTM C990

27.3 Gallons /Inch

1500 Gallon Pump Tank

Excavation: 7'9" x 9'

02/26/26